

Corporate Office:

P.O. Box 356 (282 Third Ave)
Sherman, MS 38869
Office: (662) 840-5945
Fax: (662) 840-5965

Jackson Office:

120 N Congress St., Suite 630
Jackson, MS 39201
www.envirocomp.net
Established in 2002

MEMORANDUM

To: Choctaw Generation Limited Partnership, LLLP – CCR Operating Record

From: Brian Ketchum, ECS

Re: Notice of Constituent Detected at Statistically Significant Levels above Groundwater Protection Standards

Date: May 7, 2020

Choctaw Generation Limited Partnership, LLLP (Choctaw Generation), located in Ackerman, Mississippi, operates a single unit electrical generation facility designed to generate electricity for dispatch to the Tennessee Valley Authority (TVA) electrical system. Choctaw Generation owns and operates an existing Ash Management Unit (AMU) required to meet the requirements for landfills under the Coal Combustion Residuals (CCR) Rule of 40 CFR 257, Subpart D.

Per the requirements of 40 CFR 257.95(g), Choctaw Generation is providing notification that an additional Appendix IV constituent has been detected at a statistically significant level (SSL) above the groundwater protection standard: **Beryllium**. Although it has been detected at a SSL, the exceedance has not yet been confirmed or verified. Choctaw Generation will complete the notification requirement of 40 CFR 257.95(g) by placing this notice in the facility's operating record on or before May 14, 2020, as required by 40 CFR 257.105(h)(8).